

From: Graves, Tom
To: [John Ragone](#); [Hilary Arther](#)
Subject: RE: 11/22/16 ZBA Meeting
Date: Monday, November 21, 2016 3:01:25 PM

Good afternoon, Hilary.

Below are the responses that we can provide at this time.

1. Stack Height: Final stack heights will be set by air emissions modeling required for the Illinois EPA application for an air permit, however indicative modeling tell us that a stack height of no more than 75' will be required. We are comfortable with a limit of 75' for the exhaust stacks and air inlet filters.
2. Fuel-Oil Storage: A final cost/benefit analysis has not been performed to optimize the volume stored onsite, however PVG is proposing a maximum of 4 Million gallons.

Thanks,
Tom

Thomas Graves \ Burns & McDonnell
Business Development Manager \ Market Strategist
O 816-822-3379 \ M 816-516-8230 \ F 816-822-3027
tgraves@burnsmcd.com

From: John Ragone [mailto:jragone@energydp.com]
Sent: Monday, November 21, 2016 9:10 AM
To: Hilary Arther <harther@boonecountyl.org>
Cc: Graves, Tom <tgraves@burnsmcd.com>
Subject: Re: 11/22/16 ZBA Meeting

Hilary. I am sorry but I do not remember Shelly asking for these items. I've copied Tom Graves who can answer definitively - I'm traveling today and would be guessing.

Thank you.

John

John Ragone
Energy Development Partners
(804) 305-3688

On Nov 21, 2016, at 10:00 AM, Hilary Arther <harther@boonecountyl.org> wrote:

Good Morning John,

I wanted to know if you had received and or responded to the two requests below? If so could I have a copy of the correspondences?

Thank you,

Hilary Arther | Land Use Planner | Boone County, Illinois

1212 Logan Avenue, Suite 102 | Belvidere, IL 61008

Phone: 815-547-6698 | Fax: 815-547-3579 | Email: harther@BooneCountyIL.Org

From: Shelly Dunham [<mailto:sdunham@fehr-graham.com>]

Sent: Monday, November 21, 2016 8:43 AM

To: Hilary Arther

Subject: RE: 11/22/16 ZBA Meeting

Hilary:

Yes, I plan to be available. Do you want me to call in at the beginning of the hearing? If so, what number should I call?

Also - did we ever get the two pieces of additional information I requested?

1. Height of stacks
2. Volume of backup (diesel) fuel to be stored on site.

I also encouraged them to have a conversation with the fire department that has jurisdiction in that area and have some sort of letter or statement from them about fire suppression capability and/or recommendation on placement of the diesel tank. Did that happen?

Thanks!

SHELLY R. DUNHAM, AICP | Senior Community Development Specialist
Fehr Graham - Engineering & Environmental

From: Hilary Arther [<mailto:harther@boonecountyil.org>]

Sent: Monday, November 21, 2016 8:37 AM

To: Shelly Dunham <sdunham@fehr-graham.com>

Cc: Ken Terrinoni <ktboone@boonecountyil.org>

Subject: 11/22/16 ZBA Meeting

Good Morning Shelly,

Hope you had a great weekend! I wanted to double check that you were available by phone tomorrow night at 7:00 CT for the Zoning Board of Appeals meeting with the Peaker Plant on the agenda?

Thank you,

Hilary Arther | Land Use Planner | Boone County, Illinois

1212 Logan Avenue, Suite 102 | Belvidere, IL 61008

Phone: 815-547-6698 | Fax: 815-547-3579 | Email: harther@BooneCountyIL.Org

<image001.jpg>